



Laboratory Testing Report

Call or Text US
(833) YESLABS, (833) 937-5227

Email Us:
orders@yeslabslc.com

Find us on the Web
WWW.YESLABSLLC.COM

| | | | | | | |
|-------------------------------|--|------------------------------------|-----------------------------|---------------------------|----------------------------|--------------|
| Property Location Information | Property: | Address: 69440 South River Road | City: White Pigeon | State: Michigan | Zip Code: 49099 | |
| General Information | Client: MI Water Operator LLC - Jonathan Garrett | | Sample Source: Private Well | | Sampled By: Water Operator | Initials: JG |
| Compliance Details | System: | | | PWSID #: | WSSN #: | |
| Date / Time Received | 11-27-2024 04:04 PM | | | County: St. Joseph County | Well Permit #: | |

Test Results

| Sample Number | Eval Number | Sample Type | Sample Location | Test Performed | Test Result | Result Pass / Fail | Date / Time Sampled | Date / Time Started | Date / Time Analyzed | Method | Unit of Measure | MCL | AL |
|---------------|-------------|-------------|-----------------|-------------------|-------------|--------------------|---------------------|---------------------|----------------------|----------------------|-----------------|----------|----|
| 274245 | | | Sample Tap | Total Coliform | Absent | P | 11-27-2024 12:49 PM | 11-27-2024 07:45 PM | 11-28-2024 07:35 PM | SM 9223 B - Colilert | per 100 mL | 0.000001 | |
| 274245 | | | Sample Tap | Total E.coli | Absent | P | 11-27-2024 12:49 PM | 11-27-2024 07:45 PM | 11-28-2024 07:35 PM | SM 9223 B - Colilert | per 100 mL | 0.000001 | |
| 274177 | | | Sample Tap | Nitrate | <0.50 | P | 11-27-2024 12:49 PM | | 11-27-2024 06:23 PM | US EPA 353.2 | mg NO3-N/L | 10 | |
| 274177 | | | Sample Tap | pH | 7.52 | | 11-27-2024 12:49 PM | | 11-27-2024 04:20 PM | Orion Star A215 | N/A | | |
| 274177 | | | Sample Tap | Temperature | 17.2 | | 11-27-2024 12:49 PM | | 11-27-2024 04:20 PM | Orion Star A215 | °C | | |
| 274177 | | | Sample Tap | Chlorine Residual | 0.0 | | 11-27-2024 12:49 PM | | 11-27-2024 04:13 PM | HACH Test Strips | ppm NaClO | | |

Edgar Ramos
Laboratory Manager

Carla Sue Snow
Laboratory Technician

Ellie Highland
Laboratory Technician

Your Environmental Services, LLC, 4609 Grape Road, STE D5, Mishawaka, Indiana 46545
Indiana Microbiology Certification: M-76-06, Indiana Chemistry Certification: C-71-04, Michigan Microbiology/Inorganic Chemistry Certification: 9995

For Assistance Interpreting Your Report Results
Please visit our website: WWW.YESLABSLLC.COM